

ADDENDUM #1

AVINGTON CHASE DRAINAGE SWALE REHABILITATION

City of Perry
741 Main Street
Perry, GA 31069

Bids Due: August 8, 2024 @ 2:00pm
Pre-Bid Meeting: July 25, 2024 @ 2:00pm (Recommended)

MUST PURCHASE PLANS TO GET ON OFFICIAL BID LIST

Send check to Integrated Science and Engineering. 1039 Sullivan Road, Ste. Newnan Ga 30265

Cost of Plans: Hard Copy - \$25.00
Electronic Copy - \$25.00

Bid Number: 2025-01
ISE Project #: 1013.2304

Date: August 5, 2024

PLEASE SEE THE FOLLOWING CHANGES TO THE CONTRACT DOCUMENTS AND TECHNICAL SPECIFICATIONS, ALL DOCUMENTS ARE ATTACHED:

1. Question: Are any permits or licenses needed?

Answer: Utility Contractors License, Land Disturbance Permit (Contractor will obtain from City of Perry community development department. Associated costs \$40/acre).

2. Question: Will INTSE provide inspections of work as part of an existing agreement with the owner?

Answer: Yes, there will be weekly inspections.

3. Question: Is staking to be provided by INTSE under an existing agreement with owner?

Answer: No, but ISE can provide construction staking for \$6,500.

4. Question: Are any shop drawings required for this project?

Answer: Yes, shop drawings are required for gabion baskets and the headwall if precast.

5. Question: Are any samples required for this project?

Answer: No.

6. Question: SC-6.09 references prevailing wage rate. Does this project require certified payroll submissions?

Answer: No

7. Question: Is the statement in the article 2.02 a.1.b referring to progress payment percentage, correct?

Answer: The statement has been updated; please see updated project manual.

8. Question: The gabion baskets are specified as 3'x3'x3', can they be 3'x3'x9'?

Answer: Yes, the gabion baskets can be 3'x3' by any length. 3' long cells are required within the basket; so, if you order a 3'x3'x9' basket, it must contain three - 3' cells. The baskets shall be hand-packed in order to completely fill.

9. Question: The 4"-8" stone is not available. Can you provide an approved stone size for the gabion baskets that is available at the Vulcan Quarry?

Answer: The Macon Vulcan Quarry sells a 6" surge that goes down to screenings. The surge will be acceptable. The baskets shall be hand-packed in order to completely fill. The drawings and bid form have been updated accordingly.

A temporary construction easement is currently being obtained to allow access along the gravel drive from the east of the project. Please see the updated drawings that reflect this change.