



MEMORANDUM

TO: Interested Bidders

FROM: Mitchell Worthington, Finance Director

DATE: November 5, 2024

SUBJECT: Bid #2025-20
SCBA Compressor – Fill Station Specifications

The City of Perry is soliciting bids from qualified vendors for the purchase of one (1) New SCBA Compressor according to the attached fill station specifications.

I ask that you strictly comply with these specifications and return the same to the City of Perry, clearly marked "BID NUMBER 2025-20", on or before 2:00 PM on November 19, 2024. Bids can be mailed or delivered to the Department of Finance - Purchasing, ATTN: Bid #2025-20, CITY OF PERRY GA, 1211 Washington Street, P O Box 2030, Perry, GA 31069. No faxes or emails are accepted. No other city office will accept bids unless specified on the bid.

The City of Perry reserves the right to accept any and all parts of this bid. We also reserve the right to reject all bids and to waive informalities.

Please include any delivery charges in your bid.

If you have any questions, please contact Kirk Crumpton at 478-988-2810.

Attachments



Bid Number 2025-20

Bid Specifications New SCBA Compressor System/Fill Station

Quantity : 1

Fire Dept

	Specifications	Able to Comply	Unable to Comply	Comments
1	Minimum 6000 psi, 10 horsepower, 13 cfm electric motor			
2	Automatic condensate draining system			
3	Low oil pressure alert/switch			
4	High-temperature alert/switch			
5	Minimum 5500psi fill station with the ability to simultaneously enclose and fill two SCBA or SCUBA bottles; Minimum of ¼" steel construction with steel tube fill pockets			
6	Safety interlock to prevent filling of cylinders while blast door is not securely locked			
7	Each fill tube shall have individual fill hoses with bleeder valves and adapters to accommodate SCOTT air pack systems.			
8	Carbon monoxide detection with arrest system			
9	Push-button start/stop switches.			
10	Fill control valves for all 4 cylinders.			
11	Adjustable fill pressure regulator			
12	One regulated auxiliary fill valve			
13	Replaceable filter cartridges			
14	Lead time of 45 days or less			
15	The price must include shipping, delivery, setup, and NFPA-acceptable air sample after installation			

Manufacturing / Model Bid

Bid Price:

Bid Valid for:

Estimated Delivery Time:



Company Name:

Address:

Contact Name:

Contact Number:

Email Address:

Authorized Signature

Date

Note: Please provide brochure and detailed list of specifications for with bid.