



Where Georgia comes together.



2022 | ANNUAL WATER QUALITY REPORT

# WATER QUALITY

## PUBLIC PARTICIPATION OPPORTUNITIES

The Perry City Council meets the first and third Tuesday of each month at 6:00 P.M. at City Hall.

Your participation or comments are welcome at these meetings.

[www.perry-ga.gov](http://www.perry-ga.gov)

## YOUR WATER MEETS ALL FEDERAL AND STATE REGULATIONS FOR WATER QUALITY

Last year we conducted more than 15,000 tests for over 78 drinking water contaminants. We only detected nine (9) contaminants with Gross Alpha. This brochure is an overview of the quality of the water we provided last year. Included are details about where your water comes from, what it contains, and how it compares to Environmental Protection Agency (EPA) standards. We are committed to providing you with this information because we want you to be informed. For more information about your water, please contact **Water Treatment Manager Travis Falcione at 478-988-2777.**



**YOUR WATER IS SAFE TO DRINK!**

**High quality water** is more than the dream of the conservationists, more than a political slogan; high quality water, in the right quantity at the right place at the right time, is essential to health, recreation, and economic growth.

**Citizens of the City of Perry can trust that your water is safe to drink.**



## SPECIAL POPULATION ADVISORY

# YOUR HEALTH IS OUR HIGHEST PRIORITY

**Some people may be more vulnerable to contaminants in drinking water than the general population.**

Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/Center for Disease Control guidelines on how to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline.

## HOTLINE

**EPA Safe Drinking Water Hotline  
1-800-426-4791**



## WHERE YOUR DRINKING WATER COMES FROM

**YOUR WATER COMES FROM WELLS WHICH DRAW FROM THE CRETACEOUS SAND AQUIFER.** These wells are protected from potential sources of contamination. Presence of certain constituents does not necessarily indicate that water poses a health risk. Source water assessment information and Wellhead Protection Plan may be obtained from City Hall.



**You may view this plan or request a copy by calling [478-988-2777](tel:478-988-2777).**

## WATER QUALITY MONITORING



To ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. We treat our water according to EPA's regulations. Food and Drug Administration regulations establish limits for contaminants in bottled water, which must provide the same protection for public health.

## UNDERSTANDING THE DATA

**The table in this report lists all the drinking water contaminants that we detected during the 2022 calendar year unless otherwise noted. ➔**

The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. Unless otherwise noted, the data presented in this table are from testing completed January 1 through December 31, 2022. The state requires the City to monitor for certain contaminants less than once per year because the concentrations of these contaminants are not expected to vary significantly from year to year. Some of the data, though representative of the water quality, is more than one year old.





# WATER QUALITY DATA

## 2022 CHEMICAL ANALYSIS

SUBSTANCE	MCL	MCLG	OUR WATER	DECTION RANGE	SAMPLE DATE	VIOLATON Y/N	TYPICAL SOURCE OF CONTAMINATION
<b>MICROBIOLOGICAL CONTAMINANTS</b>							
Total Coliform Bacteria	Presence of coliform bacteria in 5% of monthly samples	0	0	0	Weekly	No	Naturally present in the environment
Fluoride (PPM)	4	2	0.88	0.22–1.54	2022	No	Erosion of natural deposits which promotes strong teeth; Discharge from fertilizer and aluminum factories
Chlorine (PPM/MCL/MRDL)	4 (MRDL)	2	1.03	0.76–1.14	2022	No	Adding disinfectant to drinking water
TTHM's (Total Trihalomethanes-PPB)	80	40	0.85	0–1.70	2022	No	By-product of drinking water chlorination
HAA5 (ug/L) [Haloacetic Acids]	60	60	0	0	2022	No	By-product of drinking water chlorination
Nitrate /Nitrite (PPM)	10	10	0	ND	2022	No	Erosion of natural deposits.
SUBSTANCE	MCL	MCLG	OUR WATER 90th PERCENTILE	NO. OF SITES ABOVE ACTION LEVEL	SAMPLE DATE	VIOLATON Y/N	TYPICAL SOURCE OF CONTAMINATION
Lead (PPB)	AL-15	15	0.46	0	June 2022	No	Corrosion of household plumbing; Erosion of natural deposits
Copper (PPB)	AL-1.3	1.3	20.3	0	June 2022	No	Corrosion of household plumbing; Erosion of natural deposits
Gross Alpha pCi/L	15	0	1.75	1.49–1.99	Quarterly 2022	No	Erosion of natural deposits
SUBSTANCE	SMCL	MCLG	OUR WATER	DETECTION RANGE	SAMPLE DATE	VIOLATON Y/N	TYPICAL SOURCE OF CONTAMINATION
<b>SECONDARY MAXIMUM CONTAMINANT LEVEL (SMCL)</b>							NON HEALTH HAZARD—ONLY EFFECTS ASTHETICS (COLOR OR TASTE) OF WATER
							Adding disinfectant to drinking water
							Water softeners can contribute to the level of sodium in the water

## TERMS AND ABBREVIATIONS *(continued)*

- **AL: Action Level**—The concentration of a contaminant which, when exceeded, triggers treatment or other requirements that a water system must follow
- **MCLG: Maximum Contaminant Level Goal**—the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
- **MRDLG: Level of a drinking water disinfectant**, below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants
- **MRDL: Maximum residual disinfectant level**—highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbiological contaminants
- **MCL: Maximum Contaminant Level**—the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLG's as feasible using the best available treatment technology
- **MFL: Million fibers per liter**
- **mremf year: Millirems per year** (a measure of radiation absorbed by the body)
- **NA: Not applicable**
- **ND: Not detectable at testing limit**
- **NTU: Nephelometric Turbidity Units**
- **pCi/L: picocuries per liter** (a measure of radioactivity)
- **ppm: parts per million or milligrams per liter**— (corresponds to one minute in two years)
- **ppb: parts per billion or micrograms per liter**— (corresponds to one minute in 2,000 years)

## TERMS AND ABBREVIATIONS

- **Turbidity:** Turbidity has no health affects. However, turbidity can interfere with disinfection and provide a medium for microbial growth. Turbidity may indicate the presence of disease-causing organisms.
- **Copper:** Copper is an essential nutrient, but some people who drink water containing copper in excess of the action level over a relatively short period of time could experience gastrointestinal distress. Some people who drink water containing copper in excess of the action level over many years could suffer liver or kidney damage. People with Wilson's disease should consult their personal doctor.
- **Fluoride:** Some people who drink water containing fluoride in excess of the MCL over many years could get bone disease, including pain and tenderness of the bones. Children may get mottled teeth.
- **Lead:** If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. It is possible that lead levels at your home may be higher than at other homes in the community as a result of materials used in your home's plumbing. When water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap from 30 seconds to two minutes before using water for cooking or drinking. If you are concerned about elevated lead levels in your home's water, you may wish to have your water tested. Additional information is available from the Safe Drinking Water Hotline (800-426-4791).



# CONTAMINANTS

## THAT MAY BE PRESENT IN SOURCE WATER BEFORE WE TREAT AND PROTECT OUR WATER SUPPLY

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk.


More information about contaminants and potential health effects can be obtained by calling the **EPA's Safe Drinking Water Hotline 800-426-4791**.



The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water before we treat it include:

➔ **Microbial contaminants**, such as viruses and bacteria, which may come



from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.

- ➔ **Inorganic contaminants**, such as salts and metals, which can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining or farming.
- ➔ **Pesticides & herbicides**, which may come from a variety of sources such as agriculture and residential use.
- ➔ **Radioactive contaminants**, which are naturally occurring.
- ➔ **Organic chemical contaminants**, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and also can come from gas stations, urban stormwater runoff, and septic systems.

## WE'RE HERE TO MAKE CERTAIN YOUR WATER IS SAFE TO DRINK

Our Water Treatment Plant Operators are on duty **12 hours a day** to ensure your water is safe and provided in adequate supply. All operators are licensed by the State of Georgia and receive continuing education to maintain a high level of proficiency and expertise. A series of tests are performed **once a day** to ensure consistent quality. These tests include: pH, Fluoride, Iron and Phosphate (corrosion inhibitor) and Chlorine Residual. **You can view this report online at [www.perry-ga.gov](http://www.perry-ga.gov)** or if you have any questions about your water quality you can visit these other informative sources:

- [www.epa.gov](http://www.epa.gov)
- [www.gaepd.org](http://www.gaepd.org)
- [www.awwa.org](http://www.awwa.org)
- [www.gawp.org](http://www.gawp.org)



A UTILITY OPERATIONS AND PUBLIC WORKS MANAGEMENT COMPANY

[www.esginc.net](http://www.esginc.net)